



DISTRIBUTION CONSTRUCTION STANDARD  
EUGENE WATER & ELECTRIC BOARD - EUGENE, OREGON

4' 8" X 7' X 6" AND 4' 8" X 7' X 1' CONCRETE RISER SECTION

Approved Mar 27, 2009  
**EC5-2.2100**  
Page 1 of 2

REV.  
**0**

**ASSEMBLY EC5-2.2101**

4' 8" X 7' X 6" CONCRETE RISER SECTION

1. 348-0000482                    1 EA    RISER CONC 4'8"X7'X6"

**ASSEMBLY EC5-2.2102**

4' 8" X 7' X 1' CONCRETE RISER SECTION

1. 348-0000483                    1 EA    RISER CONC 4'8"X7'X1'

**DESIGN NOTES:**

1. Designed for H20 "Traffic Rated" wheel loading. These risers when used with a traffic rated lid, can be located in roadways, alleys, driveways, truck parking areas, fire truck access locations and airport vehicle traffic areas. These risers are NOT designed for any size of "Aircraft" wheel loading and SHALL NOT be located in these areas.

**REFERENCE STANDARDS:**

A) Refer to EC5-2.2700 for 4' 8" x 7' x 4' concrete vault.

B) Refer to Specification ES5-2.1100.02A for EWEB Stock code # 348-0000482.

C) Refer to Specification ES5-2.1100.02B for EWEB Stock code # 348-0000483.

**DISTRIBUTION CONSTRUCTION STANDARD  
EUGENE WATER & ELECTRIC BOARD - EUGENE, OREGON**

**4' 8" X 7' X 6" AND 4' 8" X 7' X 1' CONCRETE RISER SECTION**

Approved Mar 27, 2009

**EC5-2.2100**

Page 2 of 2

**REV.  
0**